

Emission Test Certificate

Wednesday January 14th, 2009

Supplier: Koolfoam Pty Ltd

54 Randall Street

Slacks Creek Queensland 4127

Product Description: Expanded Polystyrene (EPS) insulation

Date Tested: December 2008

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Expanded Polystyrene	Total Volatile Organic Compound Specific Area Emission Rate <i>mg/m²/hr</i>
24 hours	<0.03
This product can be classed as low VOC-emitting. The material emissions are less than the recognised threshold of 0.5 mg/m ² /hr; e.g. "Green Star".	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV081210